

Farmacja 2 / ZCEil

CENTRALE	SZEROKOŚĆ	WYSOKOŚĆ	DŁUGOŚĆ	KLASA	ILOŚĆ SZTUK
<b>HVACC1</b>					
NAWIEW	590	590	500	F5	2
	590	287	500	F5	2
	590	590	590	F7	2
	590	287	590	F7	2
	590	590	590	F9	2
	590	287	590	F9	2
WYWIEW	590	590	360	G4	2
	590	287	360	G4	2
					<b>16</b>
<b>HVACC2</b>					
NAWIEW	590	590	500	F5	6
	287	590	500	F5	3
	590	590	590	F7	6
	287	590	590	F7	3
	590	590	590	F9	6
	287	590	590	F9	3
WYWIEW	590	590	360	G4	4
	590	287	360	G4	2
	590	287	360	G4	3
	879	287	360	G4	1
					<b>37</b>
<b>NC1</b>					
NAWIEW	490	590	500	F5	4
	490	287	500	F5	2
	590	590	500	F5	2
	590	287	500	F5	1
WYWIEW	490	590	360	G4	4
	490	287	360	G4	2
	590	590	360	G4	2
	590	287	360	G4	1
					<b>18</b>
<b>NC2</b>					
NAWIEW	590	490	500	F5	1
	879	287	500	F5	1
	287	490	500	F5	1
WYWIEW	879	287	360	G4	1
	287	490	360	G4	1
	590	490	360	G4	1
					<b>6</b>
<b>HVACC3</b>					
NAWIEW	590	490	500	F5	1
	287	490	500	F5	1
	590	490	590	F7	1
	287	490	590	F7	1
WYWIEW	590	490	360	G4	1
	287	490	360	G4	1
					<b>6</b>
<b>HVACC4</b>					
NAWIEW	590	490	500	F5	1
	287	490	500	F5	1

Farmacja 2 / ZCEil

CENTRALE	SZEROKOŚĆ	WYSOKOŚĆ	DŁUGOŚĆ	KLASA	ILOŚĆ SZTUK
	590	490	590	F7	1
	287	490	590	F7	1
WYWIEW	590	490	360	G4	1
	287	490	360	G4	1
					<b>6</b>
<b>NA1</b>					
NAWIEW	590	590	500	F5	2
	590	490	500	F5	2
	287	590	500	F5	1
	287	490	500	F5	1
WYWIEW	590	590	360	G4	2
	590	490	360	G4	2
	287	590	360	G4	1
	287	490	360	G4	1
					<b>12</b>
<b>NA4</b>					
NAWIEW	590	590	500	F5	4
	287	590	500	F5	2
	590	287	500	F5	1
	879	287	500	F5	1
WYWIEW	590	590	360	G4	4
	287	590	360	G4	2
	590	287	360	G4	1
	879	287	360	G4	1
					<b>16</b>
<b>NA3</b>					
NAWIEW	590	590	500	F5	2
	590	287	500	F5	2
WYWIEW	590	590	360	G4	2
	590	287	360	G4	2
					<b>8</b>
<b>NA5</b>					
NAWIEW	590	590	500	F5	2
	287	590	500	F5	1
	590	287	500	F5	1
	879	287	500	F5	1
WYWIEW	590	590	360	G4	2
	287	590	360	G4	1
	590	287	360	G4	1
	879	287	360	G4	1
					<b>10</b>
<b>HVACA2</b>	590	590	300	F11-HEPA	4
NAWIEW	590	590	590	F9	4
	590	590	590	F7	4
WYWIEW	590	590	360	G4	4
					<b>16</b>
<b>HVACA1</b>					
NAWIEW	590	490	590	F9	1
	879	287	590	F9	1
	287	490	590	F9	1
	590	490	500	F5	1

## Farmacja 2 / ZCEil

CENTRALE	SZEROKOŚĆ	WYSOKOŚĆ	DŁUGOŚĆ	KLASA	ILOŚĆ SZTUK
	879	287	500	F5	1
	287	490	500	F5	1
<b>WYWIEW</b>	590	490	360	G4	1
	879	287	360	G4	1
	287	490	360	G4	1
					<b>9</b>
<b>NA2</b>					
NAWIEW	590	590	500	F5	2
	590	490	500	F5	2
	287	590	500	F5	1
	287	490	500	F5	1
WYWIEW	590	590	360	G4	2
	590	490	360	G4	2
	287	590	360	G4	1
	287	490	360	G4	1
					<b>12</b>
<b>NA7</b>					
NAWIEW	590	590	500	F5	4
	287	590	500	F5	2
WYWIEW	590	590	360	G4	4
	287	590	360	G4	2
					<b>12</b>
<b>HVACB2</b>					
NAWIEW	590	<b>590</b>	500	F5	2
	590	287	500	F5	2
	590	590	500	F7	2
	590	287	500	F7	2
	590	590	590	F9	2
	590	287	590	F9	2
WYWIEW	590	590	360	G4	2
	590	287	360	G4	2
					<b>16</b>
<b>HVACB6</b>					
NAWIEW	590	490	590	F7	1
	590	490	500	F5	1
WYWIEW	590	490	360	G4	1
					<b>3</b>
<b>NB3</b>					
NAWIEW	490	490	500	F5	2
	490	287	500	F5	2
WYWIEW	490	490	360	G4	2
	490	287	360	G4	2
					<b>8</b>
<b>NB2</b>					
NAWIEW	590	590	500	F5	2
	590	287	500	F5	2
WYWIEW	590	590	360	G4	2
	590	287	360	G4	2
					<b>8</b>
<b>HVACB5</b>					

CENTRALE	SZEROKOŚĆ	WYSOKOŚĆ	DŁUGOŚĆ	KLASA	ILOŚĆ SZTUK
NAWIEW	590	490	590	F7	1
	590	490	500	F5	1
WYWIEW	590	490	360	G4	1
					<b>3</b>
<b>NB1</b>					
NAWIEW	590	590	500	F5	4
WYWIEW	590	590	360	G4	4
					<b>8</b>
<b>HVACB3</b>					
NAWIEW	590	590	500	F5	2
	590	287	500	F5	2
	590	590	590	F9	2
	590	287	590	F9	2
WYWIEW	<b>590</b>	590	360	G4	2
	590	287	360	G4	2
					<b>12</b>
<b>HVACB4</b>					
NAWIEW	590	490	500	F5	1
	879	287	500	F5	1
	287	490	500	F5	1
	590	490	590	F7	1
	879	287	590	F7	1
	287	490	590	F7	1
WYWIEW	590	490	360	G4	1
	879	287	360	G4	1
	287	490	360	G4	1
					<b>9</b>
<b>HVACB1</b>					
	590	590	300	H11-HEPA	4
NAWIEW	590	590	590	F7	4
	590	590	590	F9	4
WYWIEW	590	590	360	G4	4
					<b>16</b>
<b>HVACA3</b>					
NAWIEW	590	590	500	F5	2
	590	287	500	F5	2
	590	590	590	F7	2
	590	287	590	F7	2
WYWIEW	590	590	360	G4	2
	590	287	360	G4	2
					<b>12</b>
<b>NA6</b>					
NAWIEW	590	590	500	F5	4
	287	590	500	F5	2
WYWIEW	590	590	360	G4	4
	287	590	360	G4	2
					<b>12</b>
<b>ND1</b>					
NAWIEW	590	490	500	F5	1

## Farmacja 2 / ZCEil

CENTRALE	SZEROKOŚĆ	WYSOKOŚĆ	DŁUGOŚĆ	KLASA	ILOŚĆ SZTUK
	287	490	500	F5	1
WYWIEW	590	490	360	G4	1
	287	490	360	G4	1
					<b>4</b>
<b>HVACD1</b>					
NAWIEW	590	490	500	F5	1
	287	490	500	F5	1
	590	490	500	F7	1
	287	490	500	F7	1
WYWIEW	287	490	360	G4	1
	590	490	360	G4	1
					<b>6</b>
<b>NA8</b>					
NAWIEW	590	490	500	F5	1
WYWIEW	590	490	360	G4	1
					<b>2</b>
<b>NB4</b>					
NAWIEW	590	<b>590</b>	500	F5	1
WYWIEW	590	<b>590</b>	360	G4	1
					<b>2</b>
				<b>OGÓŁEM</b>	<b>305</b>